

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:37 pm

PWS ID: UTAH22029 **Name:** HIDDEN LAKE ASSOCIATION
Legal Contact: HIDDEN LAKE ASSOCIATION **Rating:** Approved
VERL MOYAR **Rating Date:** 04/09/1996
Address: PO BOX 352 **Activity Status:** Active
OAKLEY, UT 84055
Phone Number: 435-783-7284
City Served (Area):
County: SUMMIT COUNTY

System Type: Non-community **Last Inv Update:** 01/05/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 09/07/2010 **Total Dsgn Cap:**
Population: 200 **Surveyor:** BRAD K HOLDAWAY **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office	Emergency	Email Address
AC	MOYAR, VERL		801-972-2728		VERLMOYAR@YAHOO.CO

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	15
			15 Total Svc Connections

Storage

Total Storage: 42,000 GAL **Number of Units:** 7 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST005	ZONE 2 6000 GAL TANK	Ground	6,000	Steel		A	NO
ST006	ZONE 2 3000 GAL TANK	Ground	3,000 GAL	Steel		I	NO
ST007	ZONE 3 RIVERSIDE TANK	Ground	6,000 GAL	Steel		A	NO
ST001	ZONE 1 15000 GAL TANK 1	Ground	15,000 GAL	Steel		A	NO
ST002	ZONE 1 15000 GAL TANK 2	Ground	15,000 GAL	Steel		A	NO
ST003	ZONE 1 10K GAL TANK 1	Ground	10,000 GAL	Steel		I	NO
ST004	ZONE 1 10K GAL TANK 2	Ground	10,000 GAL	Steel		I	NO

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	UPPER SPRINGS	Inactive	SP				No	GW	Other		
WS002	MIDDLE SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS003	RIVERSIDE SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS004	HIDDEN LAKE WELL #2	Active	WL	8	50 GPM	50 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.